



DRAWING INDEX

- E.00 - TITLE PAGE
- E.01 - FIRST FLOOR LAYOUT
- E.02 - BASEMENT AND SECOND FLOOR LAYOUT

PROJECT MEMBERS

ENGINEERING:

EME ENGINEERING INC.
231 BAYVIEW DR., UNIT L101
BARRIE, ON, L4N 4Y5

CONTACT: CHRIS LANGFORD, P.ENG
TEL: 705-220-6181
EMAIL: CHRIS@EMEENG.COM

CLIENT:

KERRY'S PLACE AUTISM SERVICES
34 BERCZY STREET, SUITE 190
AURORA, ON, L4G 1W9

CONTACT: BRUCE FERGUSON
TEL: 905-841-6611 EXT.351
EMAIL: BFERGUSON@KERRYSPLACE.ORG

CONTRACTORS:

D & L FIRE PROTECTION
15-320 HARRY WALKER PKWY
NEWMARKET, ON, L3Y 7B4
CONTACT: DARYL CHAISSON
TEL: 905-898-6204

WAKEFIELD ENTERPRISES -- ELECTRICIAN
1182638 ONTARIO LTD
969 GORHAM DR.
NEWMARKET, ON, L3Y 5C9
CONTACT: ROBERT WAKEFIELD
TEL: 416-254-7119

PROJECT MANAGEMENT
UPPER CANADA MILLWORK
22 JOHNSON RD
AURORA, ON, L4G 2A2
CONTACT: DAN SHERRARD
TEL: 416-460-9284

GENERAL NOTES:

- INSTALLATION OF MAGNETIC DOOR LOCKS TO CONFORM TO THE FOLLOWING:
 - ONTARIO BUILDING CODE 2012
 - ONTARIO ELECTRICAL CODE 2012
 - NATIONAL FIRE ALARM AND SIGNALING CODE
 - CAN/ULC S524-14
 - ONTARIO FIRE CODE
 - LOCAL MUNICIPALITY BY LAWS
 - MANUFACTURER REQUIREMENTS
- CONTRACTOR TO SUPPLY AND INSTALL MAGNETIC DOOR LOCK DEVICES
- FIRE ALARM SYSTEMS SHALL BE INSTALLED IN CONFORMANCE WITH CAN/ULC-S537, "INSTALLATION OF FIRE ALARM SYSTEMS".
- A FIRE ALARM SYSTEM SHALL BE VERIFIED IN CONFORMANCE WITH CAN/ULC-S537, VERIFICATION OF FIRE ALARM SYSTEMS", TO ENSURE SATISFACTORY INSTALLATION.
- WHERE LIFE SAFETY AND FIRE PROTECTION SYSTEMS ARE INSTALLED TO COMPLY WITH THE PROVISIONS OF THE OBC 2012 OR THE FIRE CODE MADE UNDER THE FIRE PROTECTION AND PREVENTION ACT, 1997, THE COMMISSIONING OF THOSE INTEGRATED SYSTEMS MUST BE PERFORMED AS A WHOLE TO ENSURE THE PROPER OPERATION AND INTER-RELATIONSHIP BETWEEN THE SYSTEMS.
- CONTRACTOR TO VERIFY ALL DEVICE LOCATIONS, AND INDICATE IN WRITING TO ENGINEER OF RECORD ANY PROPOSED DEVIATION FROM RECORD DRAWINGS.
- VERIFICATION OF COMPLETED FIRE ALARM SYSTEM SHALL BE PERFORMED BY THE MANUFACTURER'S REPRESENTATIVE AUTHORIZED BY THE CFAA. VERIFICATION BY THE CONTRACTOR SHALL NOT BE PERMITTED.

RECEIVED

MAY 0 9 2016

[Handwritten Signature]
FILE COPY

EME Engineering Inc. Barrie, Ontario
231 Bayview Dr., Unit L101 L4N1W5

EME ENGINEERING

ELECTRICAL MECHANICAL ENERGY

CLIENT

Kerry's Place
Autism Services
Services en autisme

PROFESSIONAL ENGINEER

C. J. LANGFORD
100114456

MAY - L
2015

PROVINCE OF ONTARIO

Drawn by: A. Langford	Date: 06/10/2015
Design by: A. Langford	Date: 06/10/2015
Checked by: C. Langford	Date: 06/03/2016

No.	Revision/Issue	Date
1	Issued for Client Review	06/10/15
2	Issued for Client Review	06/15/15
3	Issued for Permit	07/08/15
4	As-Built as per Contractor	05/03/16

Project Name/No
KERRY'S PLACE
3820 DOANE RD
MOUNT ALBERT, ON
EME Proj # 20150139

Drawing Title
TITLE PAGE

Project Name Kerry's Place	Drawing # E.00
Date 06/10/2015	
Scale N/S	

FILE COPY