

Fire Alarm and Life Safety System Inspection Certificate

For

Kerry's Place Autism Services

Building Number: 741746

Tested to CAN/ULC S536-04 Standard
Smoke alarms are inspected to CAN ULC S553-02

This report should be accompanied by the BRForm containing the contents of CAN/ULC S536-04 Appendix E

This Inspection was performed in accordance with applicable ULC Standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

The devices in this report are 100% tested and 100% passed

Annual Inspection

Start Date: Jul 25, 2025

End Date: Jul 25, 2025

Service - Tested

Building: Kerry's Place Autism Services
Contact: Tanya Vaughan

Company: D & L Fire Protection Limited
Contact: Darin Mills

To obtain further details about this inspection please utilize your login and password to view online.
This FireScan report should be accompanied with the associated BRForm.

Fire Alarm Testing Report

Executive Summary

Generated by: BuildingReports.ca

Building Information		
Building: Kerry's Place Autism Services	Contact: Tanya Vaughan	
Address:	Phone: 905-841-6611 x 351	
Address:	City/Province/Postal Code:	
Email: tanya.vaughan@kerrysplace.org		
Inspection Performed By		
Company: D & L Fire Protection Limited	Inspector: Darin Mills	
Address: 320 Harry Walker Pkwy N. #15	Phone: 9059536705	
Address:	City/Province/Postal Code: Newmarket, Ontario L3Y7B4	
Email: dlfire@rogers.com		
Monitoring		
Company: Yes Monitored	Phone:	Account #:
Certification		
Company: D & L Fire Protection Limited	Building: Kerry's Place Autism Services	
Inspector: Darin Mills	Contact: Tanya Vaughan	

Individual Device Record

Generated by: BuildingReports.ca

Type of Inspection: Fire Alarm System Annual Inspection and Test (ULC S536-04)

Building Name: Kerry's Place Autism Services

Inspection Date and Time: 7/25/25 12:36:17 PM

Inspector: Darin Mills

Note: The Location Column includes the location, time and date of the inspection and barcode number.

Remarks Column: Detector sensitivity in percentage and Waterflow Switch time delay in seconds.

For specific output circuit operation confirmation see associated BRForm section - "Ancillary Function Testing"

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
Tested									
Basement Furnace room 10 year Lithium, 12:18:59PM 07/25 /2025 (91038569)	Multi-Criteria Smoke Alarm, Smoke/CO	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
Basement Southeast Bedroom 3xAA New July 2023, 12:20:25PM 07/25/2025 (46321682)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
Basement Bottom of Stairs 3xAA New July 2024, 12:36:17PM 07/25/2025 (46321685)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
Basement North Living Room 3xAA New July 2024, 12:36:13PM 07/25/2025 (46321684)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
Basement Southwest Furnace Room 3xAA New July 2024, 12:36:07PM 07/25/2025 (46321683)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
Basement Bottom of Stairs New 9v July 2024, 12:17:22PM 07/25 /2025 (46321686)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
1st Southeast Bedroom 10 year Lithium, 12:11:56PM 07/25 /2025 (57016649)	Multi-Criteria Smoke Alarm, Smoke/CO	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
1st Laundry room 10 year lithium, 12:27:57PM 07/25/2025 (91038570)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
1st Front Hall 3xAA New July 2023, 12:08:27PM 07/25/2025 (46321692)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
1st Dining Room 3xAA New July 2024, 12:12:29PM 07/25/2025 (46321691)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025

Location	Device Type	Correctly Installed	Requires Service, Repairs, Cleaning or Missing	Alarm Operation Confirmed	Annunciation Indication Confirmed	Zone Circuit Number or Address	Supervision of Wiring Device Confirmed	Ground Circuit Confirmed	Remarks/ Readings
1st Office 3xAA New July 2024, 12:07:26PM 07/25/2025 (46321690)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
1st Laundry Room 3xAA-New July 2024, 12:30:17PM 07/25 /2025 (57016650)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
1st hall by kitchen 9 v New July 2024, 12:09:29PM 07/25/2025 (91038568)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
2nd Floor Hallway 10 year lithium, 12:12:54PM 07/25/2025 (46321688)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
2nd Southeast Floor bedroom 10 year lithium, 12:14:22PM 07/25 /2025 (91038571)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
2nd Floor bedroom 3 10 year Lithium, 12:13:41PM 07/25/2025 (75688608)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
2nd Floor bedroom 4 10 year Lithium, 12:13:56PM 07/25/2025 (75688609)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
2nd Floor bedroom 1 3xAA New July 2024, 12:15:17PM 07/25 /2025 (75688606)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
2nd Floor bedroom 2 3xAA New July 2024, 12:17:15PM 07/25 /2025 (75688607)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025
2nd Floor hallway 3xAA New July 2024, 12:13:03PM 07/25/2025 (46321687)	Smoke Alarm	☒	☐	☐	☐	1	☐	☐	LTD 07/25 /2025

Inspection & Testing

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services			Control Panel: 1	
The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.				
Device Type	Location	Service	Time	Date
Passed				
Initiating				
Multi-Criteria Smoke Alarm	Basement Furnace room 10 year Lithium	Tested	12:18:59 PM	07/25/2025
Multi-Criteria Smoke Alarm	1st Southeast Bedroom 10 year Lithium	Tested	12:11:56 PM	07/25/2025
Smoke Alarm	2nd Floor bedroom 1 3xAA New July 2024	Tested	12:15:17 PM	07/25/2025
Smoke Alarm	2nd Floor bedroom 2 3xAA New July 2024	Tested	12:17:15 PM	07/25/2025
Smoke Alarm	2nd Floor bedroom 3 10 year Lithium	Tested	12:13:41 PM	07/25/2025
Smoke Alarm	2nd Floor bedroom 4 10 year Lithium	Tested	12:13:56 PM	07/25/2025
Smoke Alarm	2nd Floor hallway 3xAA New July 2024	Tested	12:13:03 PM	07/25/2025
Smoke Alarm	Basement Bottom of Stairs 3xAA New July 2024	Tested	12:36:17 PM	07/25/2025
Smoke Alarm	Basement Bottom of Stairs New 9v July 2024	Tested	12:17:22 PM	07/25/2025
Smoke Alarm	Basement North Living Room 3xAA New July 2024	Tested	12:36:13 PM	07/25/2025
Smoke Alarm	Basement Southeast Bedroom 3xAA New July 2023	Tested	12:20:25 PM	07/25/2025
Smoke Alarm	Basement Southwest Furnace Room 3xAA New July 2024	Tested	12:36:07 PM	07/25/2025
Smoke Alarm	1st Dining Room 3xAA New July 2024	Tested	12:12:29 PM	07/25/2025
Smoke Alarm	1st Front Hall 3xAA New July 2023	Tested	12:08:27 PM	07/25/2025
Smoke Alarm	1st Laundry Room 3xAA-New July 2024	Tested	12:30:17 PM	07/25/2025
Smoke Alarm	1st Laundry room 10 year lithium	Tested	12:27:57 PM	07/25/2025
Smoke Alarm	1st Office 3xAA New July 2024	Tested	12:07:26 PM	07/25/2025
Smoke Alarm	1st hall by kitchen 9 v New July 2024	Tested	12:09:29 PM	07/25/2025
Smoke Alarm	2nd Floor Hallway 10 year lithium	Tested	12:12:54 PM	07/25/2025
Smoke Alarm	2nd Southeast Floor bedroom 10 year lithium	Tested	12:14:22 PM	07/25/2025

Smoke Alarms

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services				
The smoke alarm report details the inspection of smoke alarms.				
Scan ID	Location	Type	Voltage	Mfr. Date
Passed				
75688606	2nd Floor bedroom 1 3xAA New July 2024	3xAA		09/27/2017
75688607	2nd Floor bedroom 2 3xAA New July 2024	3xAA		09/27/2017
75688608	2nd Floor bedroom 3 10 year Lithium	Combo SA/CO		11/02/2017
75688609	2nd Floor bedroom 4 10 year Lithium	Combo SA/CO		11/02/2017
46321687	2nd Floor hallway 3xAA New July 2024	3xAA		09/27/2017
46321685	Basement Bottom of Stairs 3xAA New July 2024	3xAA		09/27/2017
46321686	Basement Bottom of Stairs New 9v July 2024		110V	08/28/2017
91038569	Basement Furnace room 10 year Lithium	Smoke/CO		01/25/2022
46321684	Basement North Living Room 3xAA New July 2024	3xAA		09/27/2017
46321682	Basement Southeast Bedroom 3xAA New July 2023	3xAA		09/27/2017
46321683	Basement Southwest Furnace Room 3xAA New July 2024	3xAA		09/27/2017
46321691	1st Dining Room 3xAA New July 2024	3xAA		09/26/2017
46321692	1st Front Hall 3xAA New July 2023	3xAA		09/27/2017
57016650	1st Laundry Room 3xAA-New July 2024	3xAA		09/27/2017
91038570	1st Laundry room 10 year lithium	Combo SA/CO	Smoke/CO	08/10/2023
46321690	1st Office 3xAA New July 2024	3xAA		09/27/2017
57016649	1st Southeast Bedroom 10 year Lithium	Smoke/CO	AC	01/25/2018
91038568	1st hall by kitchen 9 v New July 2024	Combo SA/CO	110V/Bat	09/27/2017
46321688	2nd Floor Hallway 10 year lithium	110V	Smoke/CO	08/10/2019
91038571	2nd Southeast Floor bedroom 10 year lithium	Ionization		08/10/2022

Inventory & Warranty Report

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services				Control Panel: 1
<i>The Inventory & Warranty Report lists each of the devices and items that are included in your Inspection Report. A complete inventory count by device type and category is provided. Items installed within the last 90 days, within the last year, and devices installed for two years or more are grouped together for easy reference.</i>				
Device or Type		Category	% of Inventory	Quantity
Multi-Criteria Smoke Alarm		Initiating	10.00%	2
Smoke Alarm		Initiating	90.00%	18
Type	Qty	Model #	Description	Install Date
<i>In Service - 1 Year to 2 Years</i>				
Kidde				
Smoke Alarm	1	i12010SCOCA	Combo SA/CO	10/06/2023
<i>In Service - 2 Years to 3 Years</i>				
Kidde				
Smoke Alarm	1	i12010SCOCA	Ionization	10/06/2022
<i>In Service - 3 Years to 5 Years</i>				
Kidde				
Multi-Criteria Smoke Alarm	1	p3101cuca	Smoke/CO	01/25/2022
Smoke Alarm	1	i12010SCOCA	110V	10/06/2020
<i>In Service - 5 Years to 10 Years</i>				
Kidde				
Multi-Criteria Smoke Alarm	1	P4010ACLEDSCOCA	Smoke/CO	01/25/2018
Smoke Alarm	2	P3010K-CA	Combo SA/CO	11/02/2017
Smoke Alarm	10	900-0201-Wireless	3xAA	09/27/2017
Smoke Alarm	1	900-0201-Wireless	Combo SA/CO	09/27/2017
Smoke Alarm	1	900-0201-Wireless	3xAA	09/26/2017
Smoke Alarm	1	i12040ACA		08/28/2017

Fire Suppression Inspection Certificate

For

Kerry's Place Autism Services

Building Number: 741746

This Inspection was performed in accordance with applicable standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

The devices in this report are 100% tested and 100% passed

Semi-Annual Inspection

Inspection Date

Jul 29, 2025

Building: Kerry's Place Autism Services
Contact: Tanya Vaughan

Company: D & L Fire Protection Limited
Contact: Darin Mills

To obtain further details about this inspection please utilize your login and password to view online.

Fire Suppression Testing Report

Executive Summary

Generated by: BuildingReports.ca

Building Information		
Building: Kerry's Place Autism Services		Contact: Tanya Vaughan
Address:		Phone: 905-841-6611 x 351
Address:		City/Province/Postal Code:
Email: tanya.vaughan@kerrysplace.org		
Inspection Performed By		
Company: D & L Fire Protection Limited		Inspector: Darin Mills
Address: 320 Harry Walker Pkwy N. #15		Phone: 9059536705
Address:		City/Province/Postal Code: Newmarket, Ontario L3Y7B4
Email: dlfire@rogers.com		
Systems Inspected		
System Type	Protected Area	Devices
Chemical	Kitchen Range	2
Certification		
Company: D & L Fire Protection Limited		Building: Kerry's Place Autism Services
Inspector: Darin Mills		Contact: Tanya Vaughan

Inspection & Testing

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
<i>Passed</i>				
Chemical Kitchen Range				
Monitoring	Kitchen	Tested	10:30:11 AM	07/29/2025
Kitchen System	Kitchen	Tested	10:30:01 AM	07/29/2025

Safety Equipment Inspection Certificate

For

Kerry's Place Autism Services

Building Number: 741746

This Inspection was performed in accordance with applicable standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

The devices in this report are 100% tested and 100% passed

*Annual Inspection
Inspection Date
Jul 25, 2025*

Building: Kerry's Place Autism Services
Contact: Tanya Vaughan

Company: D & L Fire Protection Limited
Contact: Darin Mills

Safety Equipment Report

Executive Summary

Generated by: BuildingReports.ca

Building Information								
Building: Kerry's Place Autism Services				Contact: Tanya Vaughan				
Address:				Phone: 905-841-6611 x 351				
Address:				City/Province/Postal Code:				
Email: tanya.vaughan@kerrysplace.org								
Inspection Performed By								
Company: D & L Fire Protection Limited				Inspector: Darin Mills				
Address: 320 Harry Walker Pkwy N. #15				Phone: 9059536705				
Address:				City/Province/Postal Code: Newmarket, Ontario L3Y7B4				
Email: dlfire@rogers.com								
Inspection Summary								
Category:	Total Items		Serviced		Passed		Failed/Other	
	Qty	%	Qty	%	Qty	%	Qty	%
Fire	8	100.00%	8	100.00%	8	100.00%	0	0.00%
Totals	8	100%	8	100.00%	8	100.00%	0	0.00%
Certification								
Company: D & L Fire Protection Limited				Building: Kerry's Place Autism Services				
Inspector: Darin Mills				Contact: Tanya Vaughan				

Notes & Recommendations

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services

The Notes & Recommendations Report details notes made by the technician during the course of the building inspection for passed devices and the inspection as a whole.

General Note

Fire Extinguishers that are supposed to be in common areas are located in Main Office. One of the Residents is violent and takes them and throws them at people

Inspection & Testing

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed /Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	ScanID : S/N	Service	Date Time
<i>Passed</i>				
Fire				
Fire Extinguisher, 5 Lbs, A.B.C.	Basement basement stairs	I-31766536 I-31766536	Inspected	07/25/25 12:06:30 PM
Fire Extinguisher, 5 Lbs, A.B.C.	Basement furnace room	86059733 I-09736661	Inspected	07/25/25 12:19:14 PM
Fire Extinguisher, 5 Lbs, A.B.C.	Basement sprinkler room	86059732 I-09736703	Inspected	07/25/25 12:26:52 PM
Fire Extinguisher, 5 Lbs, A.B.C.	1st front entrance	86058639 XC-495156	Inspected	07/25/25 12:06:16 PM
Fire Extinguisher, 5 Lbs, A.B.C.	1st garage	86059731 I-08001186	Inspected	07/25/25 12:30:32 PM
Fire Extinguisher, 5 Lbs, A.B.C.	1st kitchen	75688044 Z813822	Inspected	07/25/25 12:31:36 PM
Fire Extinguisher, 5 Lbs, A.B.C.	1st laundry room	86058638 C99762474	Inspected	07/25/25 12:27:38 PM
Fire Extinguisher, 5 Lbs, A.B.C.	2nd hallway	AE252335 AE252335	Inspected	07/25/25 12:06:57 PM

Sprinkler Inspection Certificate

For

Kerry's Place Autism Services

Building Number: 741746

This Inspection was performed in accordance with applicable standards. The subsequent pages of this report provide performance measurements, listed ranges of acceptable results, and complete documentation of the inspection. Whenever discrepancies exist between acceptable performance standards and actual test results, notes and/or recommended solutions have been proposed or provided for immediate review and approval.

The devices in this report are 100% tested and 100% passed

Annual Inspection

Inspection Date

Jul 25, 2025

Building: Kerry's Place Autism Services
Contact: Tanya Vaughan

Company: D & L Fire Protection Limited
Contact: Darin Mills

To obtain further details about this inspection please utilize your login and password to view online. This SprinklerScan report should be accompanied with the associated BRForm.

Sprinkler Inspection Report

Executive Summary

Generated by: BuildingReports.ca

Building Information									
Building: Kerry's Place Autism Services				Contact: Tanya Vaughan					
Address:				Phone: 905-841-6611 x 351					
Address:				City/Province/Postal Code:					
Email: tanya.vaughan@kerrysplace.org									
Inspection Performed By									
Company: D & L Fire Protection Limited				Inspector: Darin Mills					
Address: 320 Harry Walker Pkwy N. #15				Phone: 9059536705					
Address:				City/Province/Postal Code: Newmarket, Ontario L3Y7B4					
Email: dlfire@rogers.com									
System Control Unit									
System Type		System Location			Protected Area			Devices	
Wet Pipe		Basement			Building-			18	
Inspection Summary									
Category:		Total Items		Serviced		Passed		Failed/Other	
		Qty	%	Qty	%	Qty	%	Qty	%
Alarm		6	33.33%	6	100.00%	6	100.00%	0	0.00%
Device		3	16.67%	3	100.00%	3	100.00%	0	0.00%
Pump		1	5.56%	1	100.00%	1	100.00%	0	0.00%
Sprinkler		2	11.11%	2	100.00%	2	100.00%	0	0.00%
Valve		6	33.33%	6	100.00%	6	100.00%	0	0.00%
Totals		18	100%	18	100.00%	18	100.00%	0	0.00%
Certification									
Company: D & L Fire Protection Limited				Building: Kerry's Place Autism Services					
Inspector: Darin Mills				Contact: Tanya Vaughan					

Inspection & Testing

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services

The Inspection & Testing section lists all of the items inspected in your building. Items are grouped by Passed or Failed/Other. Items are listed by Category. Each item includes the services performed, and the time & date at which testing occurred.

Device Type	Location	Service	Time	Date
Passed				
Basement Wet Pipe, Building-				
Pressure Switch	Basement	Annual	12:23:32 PM	07/25/2025
Tamper Switch	Basement	Annual	12:23:04 PM	07/25/2025
Tamper Switch	Basement Tank 1	Annual	12:24:34 PM	07/25/2025
Tamper Switch	Basement Tank 2	Annual	12:24:38 PM	07/25/2025
Tamper Switch	Basement Tank 3	Annual	12:24:40 PM	07/25/2025
Waterflow Switch	Basement	Annual	12:23:11 PM	07/25/2025
Electric Bell	Basement	Tested	12:26:36 PM	07/25/2025
Gauge	Basement	Annual	12:24:04 PM	07/25/2025
Water Storage Tank	Basement	Annual	12:23:43 PM	07/25/2025
Electrical Driver	Basement	Annual	12:23:37 PM	07/25/2025
Sprinkler Box	Basement	Annual	12:24:57 PM	07/25/2025
Sprinkler Box	Basement	Annual	12:24:53 PM	07/25/2025
Spares				
Control Valve	Basement	Annual	12:24:25 PM	07/25/2025
Control Valve	Basement	Annual	12:25:13 PM	07/25/2025
Control Valve	Basement	Annual	12:25:23 PM	07/25/2025
Control Valve	Basement	Annual	12:25:27 PM	07/25/2025
Control Valve	Basement	Annual	12:26:09 PM	07/25/2025
Inspector's Test	Basement	Annual	12:25:46 PM	07/25/2025

Wet Pipe Fire Sprinkler Systems

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services						Basement, Building-	
<i>This section lists out all the devices and components that have been associated with a Wet Pipe System and provides details as to type of component, pressure readings, response time, etc. If a component has an OK checkbox that is checked, then that component was actually tested. However, for Pass/Fail test results, see the Inspection and Testing section.</i>							
Electrical Driver							
Location		Manufacturer	Model #	Serial #		OK	ScanID
Basement		General Air	XPS18A04	215966-53		☒	49207344
Full Speed	Pump Run Time	Volts	Amps	Horsepower		Rated Speed	
10 seconds		230	9.8	2HP		2850	
Alarms							
Pressure Switch							
Type	Description	Manufacturer	Low	High	Zone/Address	OK	ScanID
On/Off		General Air	42	62		☒	49207345
Tamper Switch							
Type	Description	Location	# of Turns	Zone/Address		OK	ScanID
Lever	Supervisory	Basement		1		☒	44669975
Lever	Supervisory	Basement Tank 1		1		☒	44669976
Lever	Supervisory	Basement Tank 2		1		☒	44669973
Lever	Supervisory	Basement Tank 3		1		☒	44669972
Waterflow Switch							
Type	Manufacturer	Model #	Sec	Size	Zone/Address	OK	ScanID
Vane	Potter	VSR-S	12	1"	1	☒	49207349
Components							
Control Valve							
Type	Location	Manufacturer	Model #		OK	ScanID	
Ball	Basement	Globe Straight	561/26		☒	49207338	
Position	Size	Status		Description			
Open	1"	Supervised		Main Control			
Control Valve							
Type	Location	Manufacturer	Model #		OK	ScanID	
Ball	Basement	Globe Straight	561/26		☒	49207339	
Position	Size	Status		Description			
Open	1"	Supervised		Tank Isolation 1			
Control Valve							
Type	Location	Manufacturer	Model #		OK	ScanID	
Ball	Basement	Globe Straight	561/26		☒	49207340	
Position	Size	Status		Description			

Open	1"	Supervised	Tank Isolation 2			
Control Valve						
Type	Location	Manufacturer	Model #	OK	ScanID	
Ball	Basement	Globe Straight	561/26	☒	49207341	
Position	Size	Status	Description			
Open	1"	Supervised	Tank Isolation 3			
Control Valve						
Type	Location	Manufacturer	Model #	OK	ScanID	
Ball	Basement	Globe		☒	49207337	
Position	Size	Status	Description			
Open	0.5"	Main Incoming				
Inspector's Test						
Manufacturer	Model #	Pressure psi	Valve Trip Time sec	Water Flow Time sec	OK	ScanID
Globe Straight	561/26	12			☒	49207348
Location						
Basement						
Devices						
Electric Bell						
Location	Size	Manufacturer	Model	OK	ScanID	
Basement		Potter	PBA-6-120	☒	49207318	
Gauge						
Type	Manufacturer	Model #	Size	Fill Type	OK	ScanID
System Pressure	General Air		1/4	Glycol	☒	49207342
Location		Service Date	Static psi	Min. Range	Max. Range	
Basement		01/18/2019	0	160		
Sprinkler Box						
Qty	Tool Available?	SIN List?	Size	Manufacturer	Location	OK ScanID
2	YES		6 unit	RedBox	Basement	☒ 49207336
Sprinkler Box Spares						
Qty	Type	Location	Manufacturer	OK	ScanID	
2	Concealed Pendant	Basement	Victaulic	☒	49207347	
Temperature		KFactor	Size	Response Time	Finish	
155		4.2		Fast Response	Brass	
Water Storage Tank						
Manufacturer	Model #	Capacity	Internal Date	Air Pressure	Temperature	OK ScanID
General	225	900	01/18/2019		Room	☒ 49207346
Type		Location				
Above ground		Basement				

Notification Report

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services			All Protected Areas	
Message, signals, signage and communications for occupants of areas protected within this inspection.				
Device Type	Type	Location	Comment	ScanID
Chemical Kitchen Range				
Monitoring		Kitchen	Passed	80915283

Chemical Fire Suppression

Generated by: BuildingReports.ca

Building: Kerry's Place Autism Services			Chemical Kitchen Range	
Dry Chemical A means of applying dry chemical that can be automatically or manually activated to discharge through a distribution system onto or into the protected hazard. The system includes auxiliary equipment. Wet Chemical An aqueous solution of organic or inorganic salts or a combination thereof that forms an extinguishing agent that can be automatically or manually activated to discharge through a distribution system onto or into the protected hazard. The system includes auxiliary equipment.				
Passed				
Device Type	Location	Manufacturer	Model Number	ScanID
Notification				
Monitoring	Kitchen	Northern Alarms		80915283
Pre-Engineered				
Kitchen System	Kitchen	Guardian	G300-B Electric	AD529490